



Project ID# 0003047835

Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

“SharpEye” Flame detectors. Models 20/20 MPI-M and 20/20 MPI-R.

Testing Category:

Fire Protection, Electrical Signaling, Alarm Signal Initiating Devices, Fire Detection, Flame-Actuated

Flame Detectors, SharpEye Models 20/20 MPI-M and 20/20 MPI-R, Triple Infrared. Each detector operates from 18 to 32 V dc via connection to a compatible FM Approved fire alarm control providing separate circuits for alarm signaling and for power. The 20/20MPI has two models: 20/20MPI-R with relay output and 20/20MPI-M with 4-20mA output. Fuels tested for response include the following: Gasoline, N-Heptane, Diesel, JP5, Kerosene, Ethyl Alcohol (95%), IPA, Methanol, Methane, LPG, Polypropylene and Paper. Detectors operating temperature is -40°C to 60°C (-40°F to 140°F). For indoor use only.

Report Issued for: Spectrex Inc.
218 Little falls Rd.
Cedar Grove, NJ 07009
United States

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Site Examination Report(s), of the following Standards and other documents:

<i>Approval</i>	<i>Date</i>	<i>Other Standards</i>	<i>Date</i>
<i>Class Number</i>		<i>Organization, Designation</i>	
ANSI/FM 3260	2004	None	
3260	2000		

Original Examination, Project Identification: 3047835

Report Issued: see below

Related Reports:None

Subsequent Revisions: None

A handwritten signature in dark ink, appearing to read 'J.E. Marquedant', is written over a horizontal line.

James Marquedant
Group Manager
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

18 July 2013
Date

