



CSIRO Verification Services Highett, Victoria, Australia +61 (0)3 9252 6000 http://www.activfire.gov.au/

Certificate of Conformity

Certificate num. Registration date Version Valid until

afp - 2816

26-Apr-2013

Number Issue date
26-Apr-2013

30-Apr-2014

Page 1 of 3

Product designation

Spectrex SharpEye™, 40/40 Series, infrared flame detectors

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Fire Protection Technologies Pty Ltd Unit 1 / 251 Ferntree Gully Road, MT WAVERLEY, VIC, AUSTRALIA, 3149

Registrant

Spectrex Inc.

218 Little Falls Road, CEDAR GROVE, NJ, UNITED STATES, 07009

Producer

Spectrex Inc.

218 Little Falls Road, CEDAR GROVE, NJ, UNITED STATES, 07009

Conformance criteria and evaluation

The Spectrex SharpEye™, 40/40 Series, infrared flame detectors has been evaluated and verified as conforming with the relevant requirements of the following criteria.

- European Standard EN 54-10:2002, 'Fire detection and fire alarm systems. Flame detectors. Point detectors'.
- 2. Loss Prevention Council Evaluation, surveillance and approval, 'LPC approval'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- Compatibility of this fire detector and with new or existing control and indicating equipment should be verified prior to installation.
- ii. Meets the requirements of EN 54-10: 2002 Class 1 at sensitivity setting 2 (default) only.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid
 if any changes or modifications
 are made to the product which
 have not been notified and
 validated by CSIRO Verification
 Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Redistrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.



Issued by

David Whittaker

Executive Officer - ActivFire Scheme



Schedule to Certificate of Conformity

| Certificate num. | Registration date | Version | | Valid until | |
|------------------|-------------------|-------------|-------------|-------------|---------------------------|
| afp - 2816 | 26-Apr-2013 | Number 1 | Issue date | 30-Apr-2014 | Page 2 of 3 |
| 4.P 2010 | | 1 | 26-Apr-2013 | | |

Producer's description

The Spectrex SharpEye™, 40/40 Series, infrared flame detectors are multi spectrum based.

The 40/40I is a conventional Class 1 triple IR (IR₃) flame detector and detects fuel and gas fires at long distances with the high immunity to false alarms.

The 40/40M is a conventional Class 1 quad IR flame detector specifically designed for detection of hydrocarbon and hydrogen flames. It detects hydrocarbon-based fuel and gas fires at long distances with the high immunity to false alarms.

Technical specification

The following details are a representative extract of the technical specification for the Spectrex SharpEye™, 40/40 Series, infrared flame detectors and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

| Model | Description |
|--------------|--------------------------------------|
| Model 40/40I | Triple Infrared (IR3) Flame Detector |
| Model 40/40M | Multi Infrared Flame Detector |

| Property/characteristic | Value(s) | | | | | | | |
|---|--|--|-----------------------------|--------------------|---|--|--|--|
| | Fuel | | 1 40/401 | Model 40/40M | | | | |
| | n-Heptane | 65 m | 215 ft | 65 m | 215 ft | | | |
| | Gasoline | 65 m | 215 ft | 65 m | 215 ft | | | |
| | Diesel Fuel | 45 m | 150 ft | 45 m | 150 ft | | | |
| Detection range | JP5 | 45 m | 150 ft | 45 m | 150 ft | | | |
| (at highest sensitivity setting for | Kerosene | 45 m | 150 ft | 45 m | 150 ft | | | |
| 0.1m ² (1ft ²) pan fire) | Ethanol 95% | 40 m | 135 ft | 40 m | 135 ft | | | |
| * 0.5m (20") high, 0.2m (8") width plume fire | Methanol | 35 m | 115 ft | 35 m | 115 ft | | | |
| ille | IPA (Isopropyl Alcohol) | 40 m | 135 ft | 40 m | 135 ft | | | |
| | Hydrogen* | not av | /ailable | 30 m | 100 ft | | | |
| | Methane* | 30 m | 100 ft | 30 m | 100 ft | | | |
| | LPG* | 30 m | 100 ft | 30 m | 100 ft | | | |
| | Polypropylene Pellets | 5 m | 16 ft | 5 m | 16 ft | | | |
| | Office Paper | 10 m | 33 ft | 10 m | 33 ft | | | |
| | | Horizo | ntal 67° | | | | | |
| Field of view | | Vertical 70° for Gasoline | | Horizontal 100° | | | | |
| I IGIQ OI VIEW | | Horizontal 80° | | Vertical 95° | | | | |
| | Vertical 80° for Hydrogen | | | | | | | |
| Spectral response | Multi IR Bands | | | | | | | |
| Response time | Typically 5 seconds | | | | | | | |
| Adjustable time delay | Up to 30 seconds | | | | | | | |
| Sensitivity ranges | 4 Sensitive ranges for 0.1 m ² (1 ft ²) n-heptane pan fire from 15 m (50 ft) to 65 m (215 ft) | | | | | | | |
| Built-in-test (BIT) | Automatic (and Manual) | | | | | | | |
| | Operating: -55°C to +75°C (-67°F to +167°F) | | | | | | | |
| Temperature range | Option: -55°C to +85°C (-67°F to +185°F) | | | | | | | |
| | Storage: -55°C to +85°C (-67°F to +185°F) | | | | | | | |
| Humidity | Up to 95% non-condensing - withstands up to 100% RH for short periods | | | | | | | |
| Heated optics | To eliminate condensation and icing on the window | | | | | | | |
| Operating voltage | 24 Vdc nominal (18-32 Vd | | | | | | | |
| Power consumption | Standby: Max. 90 mA (110 mA with heated window) | | | | | | | |
| i ower consumption | Alarm: Max. 130 mA (160 mA with heated window) | | | | | | | |
| Cable entries | 2 x 3/4" - 14NPT conduits | | 5 mm ISO | | | | | |
| Wiring | 12 - 22AWG (2.5 mm ² - 0.3 mm ²) | | | | | | | |
| Electrical input protection | According to MIL-STD-12 | | | | | | | |
| Electromagnetic compatibility | EMI/RFI protected to EN6 | | | | | | | |
| Electrical interface | The detector includes twe | | | ng options (factor | y set) | | | |
| | Stainless Steel 316L v | | | | | | | |
| Materials | Heavy duty copper free aluminum (less than 1%), red epoxy enamel finish | | | | า | | | |
| Materials Enclosure options | Stainless Steel 316L with electro polish finish | | | | | | | |
| Enclosure options | | electro polish fir | nisn | | Detector 101.6 x 117 x 157 mm (4" x 4.6" x 6.18") | | | |
| | Stainless Steel 316L with | | | | | | | |
| Enclosure options Mounting Dimensions | Stainless Steel 316L with Detector 101.6 x 117 x 15 | 7 mm (4" x 4.6" | x 6.18") | | | | | |
| Enclosure options Mounting | Stainless Steel 316L with Detector 101.6 x 117 x 15 Detector (St.St.) 2.8 kg (6 | 7 mm (4" x 4.6" .1 lb) Tilt mount | x 6.18") | | | | | |
| Enclosure options Mounting Dimensions | Stainless Steel 316L with Detector 101.6 x 117 x 15 | 7 mm (4" x 4.6" .1 lb) Tilt mount g (2.8 lb) | x 6.18") 1.0 kg (2.2 lb) | lechanical Shock | High Temp | | | |

Schedule to Certificate of Conformity

| Certificate num. | Registration date | Version | | Valid until | |
|------------------|-------------------|-------------|---------------------------|-------------|---------------------------|
| afp - 2816 | 26-Apr-2013 | Number 1 | Issue date 26-Apr-2013 | 30-Apr-2014 | Page 3 of 3 |

| Property/characteristic | Value(s) |
|-------------------------|--|
| Water and dust | IP66 and IP67 per EN60529, NEMA 250 6P |

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

| Reference | | | Data issued | | |
|------------------------------|--------------------------------------|---|-------------|------------------------|--|
| Ident. type | ldent. | Title / description Date issued (or date validated) | | Source | |
| Certificate No. | 911a-(cl-1) | Flame Detectors EN 54-10: 2011 + A1: 2005 SharpEye 40/40I | 26-Apr-2013 | LPCB, UK | |
| EC-Certificate of Conformity | 0832 – CPD – 0977 Issue num. 1 | 40/40I Conventional Class 1 triple IR (IR3) flame detector for use in fire detection and alarm systems EN 54-10:2002, 'Fire detection and fire alarm systems. Flame detectors. Point detectors' | 24 Apr 2000 | BRE Global & LPCB, UK | |
| | 0832 – CPD – 0972 Issue num. 1 | 40/40M Conventional Class 1 quad IR 9IR3) flame detector for use in fire detection and alarm systems EN 54-10:2002, 'Fire detection and fire alarm systems. Flame detectors. Point detectors' | 24-Apr-2009 | | |
| Datasheet | DS-F-40/40I | 40/40I Triple IR (IR3) Flame Detector | Nov-2012 | Spectroy Inc. N.I. LIS | |
| | DS-F-40/40M | 40/40M Multi IR Flame Detector | Mar-2012 | Spectrex Inc., NJ, US | |