

CARBON MONOXIDE ALARM WITH NEW SENSOR TECHNOLOGY:

- New sensor technology
 Electrochemical sensor immediate and stable
 sensing reduces false alarms
 Ultra-low current draw 4 mA
 Long sensor life Approx. 7 year End of Life (EOL)
- Multiple location warning
 All connected CMD5-MxI Alarms sound together
- Compact design for inconspicuous protection
 Modern design blends in with interior decor
- Battery operated version requires no power wiring Reduced labor and material costs to install Maintenance-free lithium-metal batteries
- Relay module available for generator shutdown
 One relay control module for multiple CO alarms

- > Xintex quality and reliability on board
 - Microprocessor controlled
 - Conformal coated circuit board for added protection
 - Time-weighted average CO measurement process constantly monitors all CO levels
 - Highly resistant to most chemicals, solvents and cleaners
 - Internal batteries or 12/24 VDC models available
 - CMD5-M Marine Series CO
 Alarms conform to UL STD 2034



Fireboy-Xintex, a global supplier of safety products, provides a variety of reliable fire detection and fire suppression products in addition to gas detection and control systems.

Pre-engineered and custom engineered fire suppression systems are available.

Due to our ongoing process of continuing improvement, specifications and features may change without notice.





How The Xintex CMD5-M CO Alarm Works:

The Xintex CMD5-M CO alarm uses a sensor operating with a microprocessor to measure Carbon Monoxide (CO) levels. Using a "Time-Weighted Average" (TWA) process, it monitors CO concentration, temperature and time to calculate levels of Carboxyhemoglobin (COHb). COHb is the degree to which the oxygen carrying capacity of the blood is impeded by the union of carbon monoxide to the hemoglobin and is expressed as a percentage. The human body absorbs CO easier than oxygen and COHb is the ratio of absorbed carbon monoxide to oxygen in the bloodstream. The CMD5-M alarm calculates this COHb as a function of time and determines the appropriate alarm response.





BATTERY POWER

BATTERY POWER

12/24 VDC

12/24 VDC POWER







Recommended Carbon Monoxide Detector Installation:

A carbon monoxide detector should be installed in each accommodation space. Small crafts with an open design may require only one detector for adequate protection. If two or more sleeping areas or spaces are partitioned then one detector should be installed in each of the spaces.



ABYC A-24 24.4.5

Enclosed accommodation compartment - one contiguous space, surrounded by permanent structure that contains all the following:

- Designated sleeping accommodations
- Galley area with sink
- Head compartment

 ϵ



Fireboy-Xintex LLC **616.735.9380** A Darley Company O-379 Lake Michigan Drive NW Grand Rapids, MI 49534

Fireboy-Xintex UK Operations Limited +44 (0) 845 389 9462 10 Holton Road / Holton Heath Trading Park, Poole Dorset BH166LT / United Kinadom