



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	Nominal K-Factor (gal/min/(psi) <sup>1/2</sup> )	Nominal Spray Angle (Degrees)	Nominal Thread Size (in.)	Finishes
RC150D	9.0	170	1 1/2	Stainless Steel w/ Kevlar Composite
RC150A	10.2	170	1 1/2	Stainless Steel w/ Kevlar Composite

Prepared for: International Fog, Inc., 6 Ferndale Road, Seven Valleys, PA 17360

Manufacturing Location: Amped I, LLC, 4410 N Ravenswood Ave, Chicago, IL 60640

FM Approvals Class: 2025

FM Approval Standard: Class Series 2021/2025 (February 2010)

Approval Identification: 3048229

Approval Granted: July 7, 2014

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne".

Richard B. Dunne  
Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group