

Type Approval Certificate



Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. **40 880 - 01 HH**

Company **FOGTEC Brandschutz GmbH & Co. KG**
Schanzenstraße 19 A
51063 Köln, GERMANY

Product Description **Fixed Water-Based Local Application Fire-Fighting System for Category-A Machinery Spaces**

Type **FOGTEC LAFF System**

Environmental Category **None**

Technical Data / Range of Application

Main components: 120 l/min high-pressure pump unit(s),
300 l s/s water break tank, section valve(s),
spray heads, control cabinet

Operating pressure: 120 bar

Spray nozzle details: - type: DK 7-04/03-O-VA
- orientation: pendent
- spacing, vertical and lateral distances see page 2

Application: Fixed local application fire fighting in category A machinery spaces and similar risks.

Test Standard **IMO MSC/Circ. 913**

Documents **See page 2**

Remarks **This certificate is valid together with our approval certificate no. 42936-02 HH.**

Valid until **2012-05-31**

Page **1 of 2**

Type Approval Symbol



File No. **II.H.01**

Hamburg, **2007-06-27**

Germanischer Lloyd

Günter Hölzer
Michael Kämpf

Günter Hölzer

Michael Kämpf

This certificate is issued on the basis of 'Guidelines for the Performance of Type Approvals Part 1. Procedure'