



GAMT.EX4447 Carbon Dioxide System Units, Total Flooding

Page Bottom

Carbon Dioxide System Units, Total Flooding

See [General Information for Carbon Dioxide System Units, Total Flooding](#)

FIKE CORP

EX4447

704 S 10TH ST

PO BOX 610

BLUE SPRINGS, MO 64015 USA

Item	Model or Part No.	Nom Pipe Size In.	Orifice Code Range
"S" Nozzle	C80-010	1/2	1.0 thru 11.5
Vent Nozzle	C80-020	1/2	1.0 thru 13.5
Baffle Nozzle	C80-030	1/2	1.0 thru 13.5
360 deg Radial Nozzle	C80-041	1/2	3.5 thru 13.0
180 deg Radial Nozzle	C80-042	1/2	3.5 thru 13.0
360 deg Radial Nozzle	C80-043	3/4	10.0 thru 19.0
180 deg Radial Nozzle	C80-044	3/4	10.0 thru 17.0
360 deg Radial Nozzle	C80-045	1	15.0 thru 25.0
180 deg Radial Nozzle	C80-046	1	15.0 thru 25.0

Last Updated on 2000-06-23

[Questions?](#)[Notice of Disclaimer](#)[Page Top](#)

Copyright © 2007 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2007 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

